



# A GIS tool for mapping of pump storage potential in Norway

Peggy Zinke (SINTEF Energy Research) &  
Fredrik Arnesen (Norwegian Water Resources and Energy Directorate)



# Background



- ❑ Large interest in Norway's potential for pumped storage hydropower (PSH) to develop renewable energy sources
- ❑ Pre-study from 2011 for southern Norway: selection of potential PSH connections based on expert knowledge
- ❑ GIS-tool: mapping for entire Norway based on documented selection criteria (first stage; no costs or reservoir interactions included)





TR A7126 - Apen

## Rapport

Økt balansekråftkapasitet i norske vannkraftverk


Innledende studie av konkrete case i Sør-Norge

**Forfatter(e)**  
 Elvind Solvang  
 Atle Harby  
 Anund Killingveit




SINTEF Energi AS  
 Energisystemer  
 2011-12-08

# GIS mapping of PSH potential in Europe





- ❑ Linking two existing reservoirs, or
- ❑ Transformation of one existing lake or reservoir to PHS by detecting a suitable site for a second reservoir

Schmidt et al. (2011);  
Mapping of potential in  
Thüringen (Germany)



**Norway:**  
Only linking of existing reservoirs,  
no construction of new ones





**Scheme of a pumped hydropower storage reservoir pair**

# GIS mapping of PSH potential in Europe

Recommendations from a PSH GIS mapping workshop (Arántegui and Tzimas, May 2012)

| Criteria                                                                                                                | Scope                        |                               |                                |                              |
|-------------------------------------------------------------------------------------------------------------------------|------------------------------|-------------------------------|--------------------------------|------------------------------|
|                                                                                                                         | National                     | Region                        | County                         | Grid                         |
| Max distance between reservoirs (km)                                                                                    | 20                           | 20                            | 20                             | 20                           |
| Minimum head (m)                                                                                                        | 50 – 200                     | 25 – 200                      | 15 – 200                       | 50 – 200                     |
| Topologies 1 & 2: minimum usable volume of existing reservoir (Hm <sup>3</sup> ), or hydropower installed capacity (MW) | 1 Hm <sup>3</sup> /<br>10 MW | 0.1 Hm <sup>3</sup> /<br>5 MW | 0.05 Hm <sup>3</sup> /<br>1 MW | 1 Hm <sup>3</sup> /<br>10 MW |
| Topology 2, assumed new reservoir size (m <sup>2</sup> )                                                                | 1 000                        | 700                           | 700                            | 1 000                        |
| Topology 2, assumed new reservoir average depth (m)                                                                     | 10                           | 7                             | 7                              | 10                           |
| Minimum distance to inhabited sites (m)                                                                                 | 2 000                        | 1 000                         | 200                            | 2 000                        |
| Minimum distance to existing transportation infrastructure (m)                                                          | 100                          | 100                           | 0                              | 100                          |
| Distance to national parks                                                                                              | 2 000                        | 1 000                         | 500                            | 2 000                        |
| Distance to Natura 2000 sites                                                                                           | 200                          | 100                           | 50                             | 200                          |
| Distance to special protection areas                                                                                    | 200                          | 100                           | 50                             | 200                          |
| Minimum distance to a UNESCO site (m)                                                                                   | 2 000                        | 1 000                         | 500                            | 2 000                        |
| Maximum distance to suitable grid connection (km)                                                                       | 20                           | 20                            | 10                             | 20                           |

Table 1: Proposed values for some of the criteria described, depending on the scope of the assessment. Minimum distances are between the new reservoir under assessment and the given feature<sup>6</sup>.


# GIS Mapping Norway

Input data (maps) from the Norwegian Mapping Authority, NVE, and Environmental Agency


Norway has 905 existing reservoirs, 886 of them with a reservoir volume of >100 000 m<sup>3</sup>

Grey:  
User-defined input  
parameters or data sets  
Green:  
Result files


## Flow chart



## Python script tools, included into ArcGIS 10 geoprocessing toolbox




# Tool 1: Topographical analysis



### Legend

- NVE Reservoirs
- PHS Lines 40 km
- Roads


## Tool 1, Step 1 (Distance cr.)



### Legend

- NVE Reservoirs
- PHS Lines, DEM
- Roads


## Tool 1, Step 2 (Terrain cr.)



## Tool 2 & 3: Production- and environmental related selection criteria

- ❑ There must be transmission capacities for the produced electricity.
- ❑ The water level changes (m/hour) in the upper reservoir and lower reservoir are limited because of environmental considerations (fish stranding etc.) and erosion issues.
- ❑ Protected areas (e.g. INON) should not be affected.





## User-defined parameters (can be varied in sensitivity tests)

**Table 3: User-defined criteria and default values used in the present study**

| Criteria                                                                                            | Unit   | Default | Note                                                                   |
|-----------------------------------------------------------------------------------------------------|--------|---------|------------------------------------------------------------------------|
| Maximum distance between reservoirs                                                                 | km     | 50      |                                                                        |
| Minimum head                                                                                        | m      | 50      |                                                                        |
| Minimum hydropower installed capacity                                                               | MW     | 100     |                                                                        |
| Maximum distance to roads                                                                           | km     | 10      |                                                                        |
| Maximum distance to suitable grid connection                                                        | km     | 20      |                                                                        |
| Maximum rate of water level change in reservoirs                                                    | m/hour | 0.13    | Based on river data                                                    |
| Minimum distance to INON areas (not affected by heavy technical installations or constructions)     | m      | 500     | Distances with respect to EIP. Update and expert assessment necessary! |
| Minimum distance to cultural landscape areas of high priority with biological and historical values | m      | 500     |                                                                        |
| Minimum distance to wild reindeer areas                                                             | m      | 2000    |                                                                        |
| Minimum distance to existing and suggested natural protection areas                                 | m      | 500     |                                                                        |


Distances with respect to EIP.  
Update and expert  
assessment necessary!

**Tool 3:  
Screening**


# Some screening results

## P-Screening-Mode


PSH potential for power production of 400, 700 and 1400 MW,  
minimum storage duration one day,  
maximum water level change rate in reservoir 0.13 m/hour





# PSH connections for three and 30 days storage



Power production >100 MW,  
Maximum water level change  
rate in reservoir 0.13 m/hour



# Performance test example: Tinnsjø (C1)



Multiple  
PSH lines

Figure 6: The Møsvatn-Tinnsjø-Kallhovd/Mår area with the PSH cases suggested by Solvang et al. (2012, left) and the GIS-screening results obtained using the P-Mode for 400, 700 and 1400 MW. Dashed lines: PSH lines which are in conflict with the environmental restriction zones.

Table 8: Net inflow from the reservoirs for Case C1


|                 |                   | Upper Reservoir: Møsvatn |                | Lower Reservoir: Tinnsjø |                |
|-----------------|-------------------|--------------------------|----------------|--------------------------|----------------|
|                 |                   | Solvang et al. (2012)    | Arnesen (2013) | Solvang et al. (2012)    | Arnesen (2013) |
| Other inflow    | m <sup>3</sup> /s |                          |                | 99.7                     |                |
| Other discharge | m <sup>3</sup> /s | 87.1                     |                | 150.2                    |                |
| Net inflow      | m <sup>3</sup> /s | -87.1                    | -90.5          | -50.5                    | -130.6         |

Different net inflow rates,  
depending on assumptions




Centre for Environmental Design of Renewable Energy

- ❑ Suggestions for improvements of some algorithms (e. g. terrain criterion)
- ❑ Inclusion of a simplified cost estimation as additional selection criterion for a test region in Telemark




# Cost estimation




NVE Guidelines for cost estimates; with some simplifications

# Testing and suggestions for improvements/development




$$E = \rho g \eta \cdot GPH \cdot V$$

$E$  = total potential energy storage (GWh)  
 $GPH$  = gross pressure height  
 $V$  = volume



Establish a minimum  $E$  to clip out lines with very low energy storage potential.



Choose the best GWh/NOK for each reservoir

C. Cortinez (2013)

# Conclusions

- ❑ The GIS tool showed high PSH potential in the mountains in the southern part of Norway, some relevant sites in Central Norway, few in North-Norway.
- ❑ Results are highly depending on net inflow due to existing power plants and reservoir interactions.
- ❑ Many of the PSH connections are in conflict with environmental restrictions. Further investigations of environmental restrictions are needed (expert assessment)!
- ❑ Suggested improvements and new routines for cost calculation and selection in case of multiple reservoir connections need to be implemented into the GIS tool.



# Thank you!

Contact: [peggy.zinke@sintef.no](mailto:peggy.zinke@sintef.no)